

**REQUEST FOR PROPOSAL  
SECURITY NEEDS ANALYSIS/SECURITY SYSTEM**

**ADDENDUM #1 – ANSWERS TO QUESTIONS RECEIVED**

***Question #1:*** Are there spare fiber strands that can be utilized to connect switches or does fiber install need to be provided in the proposal?

***Answer #1:*** The vendor does need to install the fiber.

***Question #2:*** Is the Town of Summerville requiring a certain size megapixel camera to be installed?

***Answer #2:*** No megapixel rating has been specified.

***Question #3:*** Is the AC system for either building plenum rated or a self-contained sealed unit?

***Answer #3:*** Neither AC system is plenum rated. The AC system in the old Town Hall Building is a traditional split system. The system in the newer Annex Building is a geothermal system.

***Question #4:*** Has the old building had Lead and Asbestos Abatement completed?

***Answer #4:*** Yes.

***Question #5:*** Is their existing conduit between the three buildings that has room for the new Fiber Runs or will contractors be required to run new conduit between the buildings. If so, are there any restrictions on construction.

***Answer #5:*** Yes, there is existing conduit.

*\*Addendum #1 posted March 14, 2016*